



6" CLASS "C" BACKFILL OR AGGREGATE BASE (SSPWC 200.03.04 & 200.01) COMPACTED TO 95%

**TYPICAL SECTION**  
NTS

**NOTES:**

1. MUELLER 18 INCH LOCKING LID (PART No. TRPL-780113) AND 27 INCH x 18 INCH FRAME.
2. MUELLER EZ-Vault METER SETTER-RIGID PVC, FACTORY EQUIPPED AS SHOWN, CONFORMING TO AWWA C800.
3. WATER METER SHALL BE NO MORE THAN 30 INCHES FROM TOP OF LID AND NOT LESS THAN 24 INCHES FROM TOP OF LID.
4. A 2 INCH METER SET REQUIRES A 2 INCH MINIMUM SERVICE LINE.
5. PIT SETTER EXTENSION, 6" TOTAL MAX. SHALL ONLY BE USED UPON APPROVAL BY CARSON CITY WATER UTILITY



NO.	REVISION	DATE	STANDARD DETAIL FOR PUBLIC WORKS CONSTRUCTION	SECTION
1	NOTE 5		<b>1 1/2" - 2"</b> <b>PIT SETTER</b>	CARSON CITY
	INSUL PAD	9/17		DRAWING NO. C-3.2.5 (203,307)
				DATE
				SEP 2017
APPROVED BY:		9/17		